


DAMPER CONTROL UNIT (MODE 6 & MODE 120 VOLT)

actionair

©RUSKIN AIR MANAGEMENT LIMITED
 South Street, Whitstable
 Kent CT5 3DU
 Telephone: 01227 276100
 Facsimile: 01227 264262
 www.actionair.co.uk



Notes:

- EXTRA PARTS NOT LISTED IN DRAWING (FOR CLARITY):
- 1, BLACK WIRE 170mm X 2 DNNN00090
 - 2, BLACK WIRE 90mm X 2 DNNN00090
 - 3, BLACK WIRE 50mm X 3 DNNN00090
 - 4, FOR DAMPER CONTROL UNIT DETAILS, REFER TO DRAWING: AA/F 6487 (FOR 230 VOLT VERSION) AA/F 9673 (FOR 120 VOLT VERSION)
 - 5, FOR NON-ETR MODES, SUBSTITUTE SIGNAL ID 4 WITH 3 AND ID 6 WITH 4.

Rev	Change	Initials	Dates

Drawn By	S.W.	06/06/2005
Checked By	J.H.	04/08/2005
Approved By	S.W.	04/08/2005
Customer	N/A	
Part No:	JNNN00061	

Title DAMPER CONTROL UNIT, WIRING DIAGRAM. 120V & 230VOLT.(DCU120 & DCU230)

Drawing No.	Revision
AA/F 9674	.

This drawing is confidential communication and is the property of Ruskin Air Management Limited and is returnable on request. It is not to be copied, loaned or communicated without the consent of Ruskin Air Management Limited. This drawing should be considered uncontrolled if it is a printed copy, or has been transmitted outside of Ruskin Air Management Limited, electronically. The live version is the electronic copy held at Ruskin Air Management Ltd. Please confirm the drawing issue before placing any orders which refer to this drawing.