


### V3 Symbols - Damper



Smoke Fire Damper (Top left red and blue arrow icons), fully open (Top right damper icon) and healthy (Green circular indicator)



Smoke Fire Damper travelling and healthy



Smoke Fire Damper fully closed and healthy



Smoke Fire Damper fully closed, healthy but not at its 'normal' position (Warning Triangle)



Smoke Fire Damper faulty (Feedback failure)



Smoke Fire Damper missing. Position unknown. (Either loss of power or communications to the SFDI)



Smoke Fire Damper fully closed and under the dictates of an environmental input (Green square)



Smoke Fire Damper fully closed and under the dictates of a Fire Alarm input (Red square)



Smoke Fire Damper fully closed and under the dictates of a Fire Fighter Override input (Yellow square)

### V3 Symbols - Group



Group Healthy (Green icon) and all dampers in group open (Bottom left damper icon)



Group Faulty (One or more dampers in group is faulty)



Group Healthy and dampers in group under the dictates of an Environmental input (Green square)



Group Healthy and dampers in group under the dictates of a Fire Alarm input (Red square)



Group Healthy and dampers in group under the dictates of a Fire Fighter input (Yellow square)

# *action*air

**Dampers Controls Fancoils**

For further explanation or assistance please contact  
Actionair Technical Support:

0044 1227 276100

**Ruskin Air Management Limited**

South Street, Whitstable, Kent

CT5 3DU England.

Tel: 01227 276100

Fax: 01227 264262

Email: [sales@actionair.co.uk](mailto:sales@actionair.co.uk)

Website: [www.actionair.co.uk](http://www.actionair.co.uk)