




### V3 Symbols




Smoke Fire Damper (Red & Grey squares within damper icon), fully open (Top right damper icon) and healthy (Green circular indicator)




Motor open/Spring closed (Blue & Red Arrows in top left corner) Smoke Fire Damper travelling and healthy




Smoke Fire Damper fully closed and healthy




Smoke Fire Damper fully closed, healthy but not at its 'normal' position (Warning Triangle)



Smoke Fire Damper faulty (Feedback failure)




Smoke Fire Damper missing. Position unknown. (Either loss of power or communications to the SFDI)




Smoke Fire Damper fully closed and under the dictates of an environmental input (Green square)

For further explanation or assistance please contact Technical Support


## V3 Symbols




Smoke Fire Damper fully closed and under the dictates of a Fire Alarm input (Red square)




Smoke Fire Damper fully closed and under the dictates of a Fire Fighter Override input (Yellow square)




Group Healthy (Green icon) and all dampers in group open (Bottom left damper icon)




Group Faulty (One or more dampers in group is faulty)



Group Healthy and dampers in group under the dictates of an Environmental input (Green square)



Group Healthy and dampers in group under the dictates of a Fire Alarm input (Red square)



Group Healthy and dampers in group under the dictates of a Fire Fighter input (Yellow square)

For further explanation or assistance please contact Technical Support


## V3 Symbols




3PSFDI-BMS Healthy (Green circle) and under the control of a BMS signal (PC Icon). Normal position unknown (Warning triangle)




3PSFDI-BMS fully closed and under the dictates of a Fire Alarm input (Red square). PC Icon turned light grey as Fire Alarm has control.



3PSFDI-LNS Under control of the Actionpac system and in balanced position (arrows on damper icon)




3PSFDI is missing (Yellow Circle) device attempting to failsafe (Arrow), actual damper position unknown (question mark).



VAVI Healthy (Green circle) and under local control by others (PC Icon). Normal signal unknown (Warning triangle)



VAVI open and under the dictates of a Fire fighter override (Yellow square) PC Icon turned light grey as Fire fighter has control



SDI Healthy (Green circle) and fully open. SDI Icon is represented by straight red and blue arrows (Drive Open / Drive Closed).

For further explanation or assistance please contact Technical Support