| Draw No. AA/F10368 | Rev. | DIMENSIONS IN MILLIMETRES | DO NOT SCALE |
|---|---|---|---|

## NON-ACCESS SIDE




1.2mm x 'X'mm ('X' DIMENSION IS 60mm, UNLESS OTHERWISE STATED) FLANGE TO DAMPER CASING WELDS MUST BE 6-10mm STITCH WELDS, IN EACH CORNER, 125mm (MAX) CENTERS, ON FRONT ONLY.





actionair

© RUSKIN AIR MANAGEMENT LIMITED
South Street, Whitstable
Kent CT5 3DU
Telephone: 01227 276100
Facsimile: 01227 264262
www.actionair.co.uk


NOTES:

1.2mm FLANGE ON NON-ACCESS SIDE.

SIDE FLANGES, JOGGLE FOLDED EACH END, FURTHER FIXED TO TOP AND BOTTOM FLANGES, BY MEANS OF SELF PIERCING RIVETS.

ALL FLANGE TO DAMPER CASING WELDS. MUST BE 6-10mm STITCH WELDS, IN EACH CORNER, 125mm (MAX) CENTERS, ON FRONT ONLY.

FOR PTC **"NON-ACCESS"** FLANGE REFER TO DRAWING AA/F9811
**"ACCESS SIDE"** FLANGE PLEASE REFER TO DRAWING AA/F9812

THIS DRAWING REPLACES DRAWINGS; AA/F 1349 & AA/F 9462

FOR TESTED INSTALLATION METHOD REFER TO DRAWINGS SF029 & SF030.

THIS METHOD WOULD BE SUBJECT TO THE SCRUTINY AND APPROVAL FROM THE RELEVANT DISTRICT SURVEYOR / LOCAL AUTHORITY PRIOR TO ORDERING.
THIS DRAWING IS NOT INTENDED TO ENDORSE THE ARRANGEMENT AS BEING SUITABLE FOR IT'S INTENDED APPLICATION.

THE INFORMATION SHOWN IS SUBJECT TO CHANGE WITHOUT NOTICE DUE TO CONTINUING RESEARCH AND DEVELOPMENT.

| Rev | Change | Dates |
|---|---|---|
| | | |
| | | |

| | | |
|---|---|---|
| Drawn by | S.W. | 11/05/2009 |
| Checked by | H.T. | 04/08/2009 |
| Approved by | M.B. | 05/08/2009 |
| Customer | | |
| Project | | |

Description

G.A. FOR 1.2mm GAUGE FLANGE
NON-ACCESS SIDE **FIRE/SHIELD**

Drawing No. Revision

AA/F10368


This drawing is confidential communication and is the property of Ruskin Air Management Limited and is returnable on request. It is not to be copied, loaned or communicated without the consent of Ruskin Air Management Limited.
This drawing should be considered uncontrolled if it is a printed copy, or has been transmitted outside of Ruskin Air Management Limited, electronically. The live version is the electronic copy held at Ruskin Air Management Ltd.
Please confirm the drawing issue before placing any orders which refer to this drawing.The Information Shown Is Subject To Change Without Notice Due To Continuing Research And Development.